



Permit Reviews

Harnett County

Permit Number: BRES2207-0072

Description: 33.25x20 Master bed addition

Applied: 7/26/2022

Approved:

Site Address: 18 TWIN OAKS DR

Issued:

Finalized:

City, State Zip Code: ANGIER, NC 27501

Status: RECEIVED

Applicant: Vuncannon & Sons Builders, Inc.

Parent Permit:

Owner: REID ASHLEY B

Parent Project:

Contractor: Vuncannon & Sons Builders, Inc.

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
7/26/2022	7/27/2022	7/27/2022	CENTRAL PERMITTING INTAKE	CP Bucket	APPROVED	
Notes:						
7/26/2022	7/26/2022	7/26/2022	RESIDENTIAL BUILDING	Building Bucket	NO REVIEW NEEDED	eng plan
Notes:						
7/27/2022	8/4/2022	8/10/2022	ENVIRONMENTAL	Andrew Currin	DISAPPROVED	Septic Encroachment
Notes: Septic Encroachment - Septic field cross off back of existing porch as consistent with existing operational permit. Field marked onsite via flags. Proposed additions unapprovable based on existing septic field location. Any septic relocation and expansion application would likely require a private soil consultant proposal.						