

June 18th, 2022

ph: 910-893-7547

fax: 910-893-9371

Travis & Amy Thomas
10 Birch Grove Lane
Coats, NC 27526

Re: Status of Permit Application-BRES2208-0010

Mr. & Mrs. Thomas,

An attempt was made to evaluate your property for issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are Set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs growth cleared
- 5. Driveway not shown on site plan (Revision Required)
- 6. Backhoe pits required
- 7. **Other-Provisionally suitable soils present in rear yard behind marked home. Lot is heavily wooded with ample available soil. Clear lot, install driveway, and re-confirm for septic layout. Note: house marked onsite is not consistent with site plan. House significantly greater than 70ft from front property line. Land use application does not show a clear bedroom count. Advised to provide revised and more detailed site plan and clear land use application. Recommended rear of house box crests top of hill (as marked onsite) or septic pump system be required.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7525 ext. 1 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh

Copy: Central Permitting