



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

1/31/2023

SUBJECT: BRES2208-0027
BUILDING RESIDENTIAL

To: Premier Pools and Spas

Here are the results of all Inspections located at **87 E T FARM LN:**

Inspection Type: GAS PIPING
Scheduled Date/Time: 10/19/2022
Completed Date/Time: 10/19/2022
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/14/2022 12:48 PM Mayra Yesenia Avila

Contact Name: Mayra Yesenia Avila
Site Address: 87 E T FARM LN
Phone: 9195794086
e-Mail: ymendoza@ppas.com

Inspection Type: ELECTRICAL UNDERGROUND
Scheduled Date/Time: 10/19/2022
Completed Date/Time: 10/19/2022
Inspector: James T Hall
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 10/14/2022 12:48 PM Mayra Yesenia Avila

Contact Name: Mayra Yesenia Avila
Site Address: 87 E T FARM LN
Phone: 9195794086
e-Mail: ymendoza@ppas.com

Inspection Type: BONDING
Scheduled Date/Time: 10/28/2022
Completed Date/Time: 10/28/2022
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: No bonding wire around pool per code



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: BONDING
Scheduled Date/Time: 11/1/2022
Completed Date/Time: 11/1/2022
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ZONING
Scheduled Date/Time: 11/4/2022
Completed Date/Time: 11/4/2022 09:45 AM
Inspector: Kyle Holder
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 1/30/2023
Completed Date/Time: 1/30/2023
Inspector: John B Kokoszka
Result: APPROVED
Remarks:
Notes: