

Pin # 0525-65-6317.000

App# BRES2208-0030

Harnett County Department of Public Health

Improvement Permit

Revised For
House
Location

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION 2698 Overhills Rd (SR 1102)

SUBDIVISION _____

LOT # _____

Site Improvements required prior to Construction Authorization Issuance: _____

ISSUED TO: Patrick PattersonNEW ☒REPAIR ☐EXPANSION ☐Type of Structure 14'x70 SWMHProposed Wastewater System Type pump to 25% reductionProjected Daily Flow 240 GPDNumber of bedrooms: 2 Number of Occupants: 4 maxBasement ☐ Yes ☒ NoPump Required: ☒ Yes ☐ No ☐ May be required based on final location and elevations of facilitiesType of Water Supply ☐ Community ☒ Public ☐ Well Distance from well: _____ feet

Permit valid for:

☒ 1 year☐ No expiration

Permit conditions: _____

Authorized State Agent: Mel A. REHSDate: 6-26-25

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies to meeting their requirements. This site is subject to relocation if the site plan, part or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958 and 1959 are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Patrick PattersonPROPERTY LOCATION: 2698 Overhills Rd (SR 1102)

SUBDIVISION _____

LOT # _____

Facility Type: 14'x70 SWMH☒ New☐ Expansion☐ RepairBasement? ☐ Yes ☒ No Basement Features? ☐ Yes ☒ NoType of Wastewater System** pump to 25% reduction(Initial) Wastewater Flow: 360 GPD(See note below, if applicable) ☐pump to 25% reduction (Repair)

Installation Requirements/Conditions:

Septic Tank Size 1000 gallonsPump Tank Size 1000 gallonsNumber of trenches 2Exact length of each trench 75 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of 18-24 inches(Trench bottoms shall be level to $\pm 1/4"$ in all directions)Trench Spacing: 9 feet on CenterSoil Cover: 6 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe

_____ inches above pipe

_____ inches total

Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable, I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature _____

Date: _____

This Construction Authorization is subject to relocation if the site plan, part or the intended use changes. This Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: Mel A. REHSDate: 6-26-25Construction Authorization Expiration Date: 6-26-30

Application # BRES2208-0030 R

Hammett County Department of Public Health Site Sketch

Property Location: 2698 Overhills Rd (SR 1102)


Issued To: Patrick Patterson

Subdivision

Lot #

Date: 6-26-25

Authorized State Agent: *PCMH*



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.