

HTE #: BRES2208-0053

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Sierra Structures

Phone #: 919-471-3500

Address: 917 Ellis Rd. Durham 27703

Name of Mobile Home Park or S/D: Atkins Place - Lot 14

Name of Owner (if different): Maria and Marty Alonso

Address of Owner (if different): 25 Atkins Place Cr

Property Location (State Road name and #): 25 Atkins Place Cir. (Atkins Rd. - SR 1448)

Purpose of Inspection: 12'x12' Deck - Built on footprint of existing deck

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM



Signature of Environmental Health Specialist

09/08/2022

Date