

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460

July 13, 2023

Subject: 125 Ruth Circle  
Fuquay Varina, NC 27526  
Plan Revision Letter  
Harnett County Permit #: BRES2208-0056

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The original beam was shown as a triple 1 3/4"x 20" LVL with 5 studs on both ends. The Contractor asked to modify the LVL beam from triple 1 3/4"x 20" beam to a double 1 3/4"x 24" LVL. This beam modification is acceptable. Install 3 studs under each end of the new double LVL beam.

The beam modification noted above meets all the requirements of the 2018 North Carolina Building Code for Residences.



07 13 2023