



Permit Inspections

Harnett County

Permit Number: BRES2209-0025

Description: **interior remodel (2052 htd sq ft)**

Applied: **9/20/2022**

Approved: **9/26/2022**

Site Address: **3330 ABATTOIR RD**

Issued: **9/28/2022**

Finalized: **3/3/2023**

City, State Zip Code: **ANGIER, NC 27501**

Status: **FINALED**

Applicant: **Amber Faw**

Parent Permit:

Owner: **FAW REALTY LLC**

Parent Project:

Contractor: **<NONE>**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FOOTING	Deen Taylor		
Notes:						
			FOUNDATION	Deen Taylor		
Notes:						
			MONO SLAB	Deen Taylor		
Notes:						
			OPEN FLOOR	Deen Taylor		
Notes:						
			SLAB	Deen Taylor		
Notes:						
			UNDER SLAB TRADES	Deen Taylor		
Notes:						
	10/17/2022	10/17/2022	ROUGH IN	Deen Taylor	APPROVED W/EXC	
Notes: Wall/door between garage and house must be fire rated. Insulate around window frames. Fire caulk electrical.						
	10/19/2022	10/19/2022	INSULATION	Deen Taylor	APPROVED	
Notes:						
	10/19/2022	10/19/2022	ROUGH IN REINSPECT	Deen Taylor	APPROVED	
Notes:						





Permit Inspections Harnett County

	11/29/2022	11/30/2022	FINAL**	Deen Taylor	DISAPPROVED	
Notes: House not ready for final, OK for power						
	3/2/2023	3/3/2023	FINAL**	Deen Taylor	APPROVED	
Notes:						

