

HTE# BAPS2210-0006

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Cleanwater Pools PHONE # 919-359-2440

ADDRESS 63-102 Anna Dr Clayton N.C. 27520

NAME OF MOBILE HOME PARK OR S/D -

NAME OF OWNER (IF DIFFERENT) Rob + Diana Scantlin

ADDRESS OF OWNER (IF DIFFERENT) 2501 Ashe Ave DUNN N.C. 28334

PROPERTY LOCATION: STATE ROAD NAME AND # 501425 Ashe Ave

PURPOSE OF INSPECTION: 14x28 Inground Pool

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

Advised to move Pool Away from DRAIN LINE 18" more Inches

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

[Signature] Signature of Environmental Health Specialist 10-20-22 Date