HARNETT COUNTY HEALTH DEPARTMENT ENVIRONMENTAL HEALTH 307 CORNELIUS HARNETT BOULEVARD LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Pannot Bay Pooles Phone #: 910-670-9375
Address: PO BOX 565 Hope Mills N.C. 28378
Name of Mobile Home Park or S/D: Prince Pointe Lof 4
Name of Owner (if different): CAsey + Kelsey Mallett
Name of Owner (if different): CASEY + Kelsey Mallett Address of Owner (if different): 5036 Christian (Eplt PiD F.V. NC 27526
Property Location (State Road name and #): SR 1412 Chaiston light 20
Purpose of Inspection: 14x30 Swemming Pool
The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.
 the intended use of the septic system should change, and/or the system should fail or malfunction, and/or the owner or tenant of the property change, and/or after six months
BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM DO NOT DRIVE OR PARK ON SEPTIC SYSTEM
AUTHORIZATION OF EXISTING SYSTEM
James & Marchant 10-26-22
Signature of Environmental Health Specialist Date