

November 15th, 2022

Josh McMahon
42 Woodstone Place
Angier, NC 27501

RE: Existing Tank Application # BRES2210-0022

Mr. McMahon

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal, uncover D-Box. (\$25.00 fee incurred).**
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other –

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JEM/kh
Copy - Central Permitting