## Harnett County Department of Public Health

## Improvement Permit A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 624 Gainsborogh Ln ISSUED TO: Clayton Homes SUBDIVISION Site Improvements required prior to Construction Authorization Issuance: EXPANSION REPAIR | Type of Structure: WMH (28'x68') Proposed Wastewater System Type: 25% Reduction Sys Projected Daily Flow: 480 Number of bedrooms: 4 Number of Occupants: 8 Basement Yes May be required based on final location and elevations of facilities ☐ No Pump Required: Yes Permit valid for: X Five years Public Well Distance from well 100 feet Type of Water Supply: Community No expiration Permit conditions: REH) Date: 11/29/22 Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: Clayton Homes PROPERTY LOCATION: 624 Gainsborogh Ln LOT # SUBDIVISION Facility Type: SWMH (28'x68') Expansion ➤ New Basement Fixtures? Yes Basement? Yes ✓ No (Initial) Wastewater Flow: 480 GPD 25% Reduction System Type of Wastewater System\*\* (See note below, if applicable ) 25% Reduction System Number of trenches 1 Installation Requirements/Conditions Exact length of each trench 300 Trench Spacing: 9 Septic Tank Size 1000 Feet on Center gallons Soil Cover: 6 Pump Tank Size \_\_\_\_\_ \_gallons Trenches shall be installed on contour at a (Maximum soil cover shall not exceed Maximum Trench Depth of: 18 inches 36" above the trench bottom) (Trench bottoms shall be level to +/-1/4" in all directions) inches below pipe Pump Requirements: ft. TDH vs. \_\_ inches above pipe Aggregate Depth: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 11/29/22 Authorized State Agent: \_ Construction Authorization Expiration Date: 11/29/27

## Harnett County Department of Public Health Site Sketch

