

HTE #: BAES2210-0049

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Brandon Barnett Phone #: 919-500-9685

Address: 130 High Standard Ln Angier N.C. 27501

Name of Mobile Home Park or S/D: Lot 37 Hunters Point

Name of Owner (if different): _____

Address of Owner (if different): _____

Property Location (State Road name and #): SR 1505 Selas Hayes Rd

Purpose of Inspection: 12x20 STORAGE SHED ALREADY IN PLACE

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markham JR RBAS
Signature of Environmental Health Specialist

11-14-22
Date