

November 16th, 2022

Donald Holder
18 Delmar Ct
Fuquay Varina, NC 27526

RE: Existing Tank Application # BRES2210-0067

Mr. Holder

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal, uncover D-Box. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary Tee with Filter
- 4. Other – Please contact James Manhart in the mornings between 8:00-9:00 am Monday through Friday 910-893-7547 in reference to the 12x10 wood deck.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JEM/kh
Copy - Central Permitting