



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

3/13/2023

**SUBJECT: BRES2211-0004**  
**BUILDING RESIDENTIAL**

To: J AND D CONTRACTOR SERVICE INC

Here are the results of all Inspections located at **308 SILVER MAPLE DR:**

Inspection Type: FOUNDATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: MONO SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: OPEN FLOOR  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: UNDER SLAB TRADES  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 12/9/2022  
Completed Date/Time: 12/9/2022  
Inspector: Justin Ryan McLeod  
Result: APPROVED W/EXC  
Remarks:  
Notes: Footing stops short of existing patio corner. Ok if bearing post is going to be just left of rear slider straight out. If bearing post will be around corner of existing patio the footing needs to extend and inspection called back in.

Inspection Type: FOOTING  
Scheduled Date/Time: 1/24/2023  
Completed Date/Time: 1/24/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time: 1/30/2023  
Completed Date/Time: 1/30/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED W/EXC  
Remarks:  
Notes: Post at the house to future screen door needs securing. Will check at final if not covering posts.

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time: 3/10/2023  
Completed Date/Time: 3/10/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 3/10/2023  
Completed Date/Time: 3/10/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 3/8/2023 4:42 PM J & D Contractor Service Inc.

Contact Name: J & D Contractor Service Inc.

Site Address: 308 SILVER MAPLE DR

Phone: 9194270218

e-Mail: [jdcontractorservice@gmail.com](mailto:jdcontractorservice@gmail.com)