

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460

April 20, 2023

Subject: Dawson Pool House
565 Cotton Road
Fuquay Varina, NC 27526
Plan Revision Letter
Harnett County Permit #: BRES2211-0021

Based on the request of the Contractor, 1 item on the plans will be revised. My assessment and recommendations are as follows:

- The Contractor wants to move the ceiling joists up to attach to the rafters. The ceiling joists have been moved up and attached to the rafters. The revised location and installation of the ceiling joists is acceptable.

The ceiling joists noted above meet all the requirements of the 2018 North Carolina Building Code for Residences.



04 20 2023