



Permit Inspections

Harnett County

Permit Number: BRES2211-0034

Description: 28x56 (3bedroom)

Applied: 11/9/2022

Approved: 3/22/2023

Site Address: 195 KEITH WEATHERS RD

Issued: 3/22/2023

Finaled: 7/14/2023

City, State Zip Code: FUQUAY-VARINA, NC 27526

Status: FINALED

Applicant: Joshua Weathers

Parent Permit:

Owner: WEATHERS JOSHUA ALAN

Parent Project:

Contractor: STATE MOBILE HOME MOVERS

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	5/26/2023	5/31/2023	ADDRESS	GIS Bucket	APPROVED	eTRAKiT Inspection Request

Notes:

5/25/2023 10:25 AM Michelle Hartley

Contact Name: Michelle Hartley

Site Address: 195 KEITH WEATHERS RD

Phone: 9108920108

e-Mail: michelle.hartley@claytonhomes.com

195 KEITH WEATHERS RD FUQUAY VARINA 27526.

	5/30/2023	5/30/2023	MH FOUND/MARRIAG E WALL	Justin Ryan McLeod	CANCELLED	eTRAKiT Inspection Request
--	-----------	-----------	-------------------------------	-----------------------	-----------	----------------------------

Notes:

5/25/2023 10:25 AM Michelle Hartley

Contact Name: Michelle Hartley

Site Address: 195 KEITH WEATHERS RD

Phone: 9108920108

e-Mail: michelle.hartley@claytonhomes.com

Cus Michelle called to cancel

	6/1/2023	6/1/2023	MH FOUND/MARRIAG E WALL	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
--	----------	----------	-------------------------------	-----------------------	----------	----------------------------

Notes:

5/30/2023 3:47 PM Michelle Hartley

Contact Name: Michelle Hartley

Site Address: 195 KEITH WEATHERS RD

Phone: 9108920108

e-Mail: michelle.hartley@claytonhomes.com



Permit Inspections

Harnett County

	6/9/2023	6/9/2023	WATER CONNECTION	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
Notes: 6/8/2023 11:53 AM Michelle Hartley Contact Name: Michelle Hartley Site Address: 195 KEITH WEATHERS RD Phone: 9108920108 e-Mail: michelle.hartley@claytonhomes.com						
	6/9/2023	6/9/2023	SEWER CONNECTION	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
Notes: 6/8/2023 11:53 AM Michelle Hartley Contact Name: Michelle Hartley Site Address: 195 KEITH WEATHERS RD Phone: 9108920108 e-Mail: michelle.hartley@claytonhomes.com						
	6/14/2023	6/14/2023	FOOTING	Justin Ryan McLeod	DISAPPROVED	eTRAKiT Inspection Request
Notes: 6/13/2023 8:40 AM Michelle Hartley Contact Name: Michelle Hartley Site Address: 195 KEITH WEATHERS RD Phone: 9108920108 e-Mail: michelle.hartley@claytonhomes.com No clear footing observed, dirt pad for AC also washed down into footing area. but this is for non structural brick underpinning.						
	7/6/2023	7/6/2023 10:00 AM	ZONING	Kyle Holder	APPROVED	eTRAKiT Inspection Request
Notes: 7/5/2023 2:58 PM Michelle Hartley Contact Name: Michelle Hartley Site Address: 195 KEITH WEATHERS RD Phone: 9108920108 e-Mail: michelle.hartley@claytonhomes.com						
	7/7/2023	7/7/2023	FOOTING	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
Notes: Used probe rod and probed projection around structure.						
40	5/11/2023	5/11/2023	ENVIR OPERATIONS PERMIT	James Manhart	APPROVED	
Notes:						



Permit Inspections Harnett County

50	7/7/2023	7/7/2023	MFH FINAL**	Justin Ryan McLeod	DISAPPROVED	
Notes: lock box 1872 1. Grade not falling away from home on right side. 2. Water heater breaker needs lockout, the lockout is Laying in bottom of the panel. 3 standing water under home that cannot flow out especially Along rear wall. 4. The steps and landing cannot use 2x4 for the legs and rail posts. 5 locate/expose ground rods.						
50	7/14/2023	7/14/2023	MFH FINAL**	Justin Ryan McLeod	APPROVED	
Notes: lock box is 1872						