



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

3/14/2023

SUBJECT: BRES2211-0054
BUILDING RESIDENTIAL

To: Stephen Overton

Here are the results of all Inspections located at **39 FIELDSTONE DR:**

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 12/29/2022
Completed Date/Time: 12/29/2022
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 2/7/2023
Completed Date/Time: 2/7/2023
Inspector: Justin Ryan McLeod
Result: DISAPPROVED
Remarks:
Notes: Missing anchor bolts each side garage door and end wall corners. Plan states to anchor within 6" of each post and end of each wall. Foundation needs backfilled around per code.

Inspection Type: FINAL**
Scheduled Date/Time: 3/10/2023
Completed Date/Time: 3/10/2023
Inspector: Justin Ryan McLeod
Result: APPROVED
Remarks:
Notes: