



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

6/7/2023

**SUBJECT: BRES2212-0014**  
**BUILDING RESIDENTIAL**

To: Robert Lee

Here are the results of all Inspections located at **310 WYNDHAM PLACE DR:**

Inspection Type: OPEN FLOOR  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN REINSPECT  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 5/19/2023  
Completed Date/Time: 5/19/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL\*\*

Scheduled Date/Time: 6/7/2023

Completed Date/Time: 6/7/2023

Inspector: Scott Guy

Result: DISAPPROVED

Remarks:

Notes: 1-(dirt) landing at bottom of step is required to be 3x3. 2-right side of step requires a guardrail .  
This area is great than 30" in height.

Inspection Type: ROUGH IN

Scheduled Date/Time: 6/7/2023

Completed Date/Time: 6/7/2023

Inspector: Scott Guy

Result: DISAPPROVED

Remarks:

Notes: Results listed on final inspection ticket