

HTE #: BUES 2301-0005

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Rocky Smith Phone #: 919 271-2163

Address: 141 Smith Dr Angier N.C. 27507

Name of Mobile Home Park or S/D: Sandy Grove lot 9

Name of Owner (if different): Alzeca + Guiseida Ramirez

Address of Owner (if different): 149 Smith Dr Angier N.C. 27507

Property Location (State Road name and #): On 1542 Old Buebs Creek Rd

Purpose of Inspection: ADDITION 2 Bed Bad office 32'x30'

**NO MODIFY Ex septic move Repair to Front Yard Pmp to*
The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marshall *JEM*
Signature of Environmental Health Specialist

1-18-23
Date