

Howerton Services, PLLC
License # P-1716
3513 Cathedral Bell Road
Raleigh, NC 27614
(919) 270-3460


March 15, 2023

Subject: 658 Truelove Road
Holly Springs, NC 27540
Detached Garage Masonry Walls Letter
Harnett County Permit #: BRES2301-0006

Based on the request of the Contractor, I reviewed the height of the masonry walls of the Detached Garage for code compliance. My assessment is as follows:

- The walls of the detached garage are 8"x 8"x 16" concrete masonry units on concrete footings. The walls are 11' tall from the top of the concrete footings to the top of the wall. The 11' CMU walls are acceptable as constructed.

The masonry walls of the Detached Garage meet all the requirements of the 2018 North Carolina Building Code for Residences.



03 15 2023