

# OPERATIONS PERMIT

Name: (owner) Alicia Ann Mabrey  New Installation  Septic Tank  
 Property Location: SR# 1564 Maple Rd  Repairs  Nitrification Line  
 Subdivision - Lot # \_\_\_\_\_  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Jay Adcock Registration # 191

Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: 50' ft.


Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field: No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.  
 French Drain: - Linear feet

Date: 7-17-00

PERMIT NO. 17454

Inspected by: James E. Manhart, Jr., P.E.  
Environmental Health Specialist



SR 1564 Maple Rd

#00-40000610

HARNETT COUNTY HEALTH DEPARTMENT

No 17454

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Alicia Ann Mabry

New Installation  Septic Tank

Property Location: SR# 1564 Maple Rd

Repairs  Nitrification Line

Subdivision - Lot # -

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 2 Lot Size: 2.0 acres

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 100' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons


Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: - Linear feet

Date: 6-28-00

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manhart Esq. Environmental Health Specialist



\* Maintain all setbacks!

\* Well to be located in position that does NOT interfere with system or repair!

512 1564 Maple Rd