Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 393 Blanchard Rd (SR 1114) ISSUED TO: Rusty Frizzelle SUBDIVISION EXPANSION Site Improvements required prior to Construction Authorization Issuance: REPAIR X Type of Structure: 14'x70' SWMH Proposed Wastewater System Type: existing New Septic tank required Projected Daily Flow: 360 Number of Occupants: 6 Number of bedrooms: 3 Basement Yes May be required based on final location and elevations of facilities X No Pump Required: Yes Type of Water Supply: Community Public Well Distance from well feet X Five years Permit valid for: ■ No expiration Permit conditions: Date: 03-08-23 SEE ATTACHED SITE SKETCH Authorized State Agent::

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout, PROPERTY LOCATION: 393 Blanchard Rd (SR 1114) ISSUED TO: Rusty Frizzelle Facility Type: 14'x70' SWMH Expansion Basement Fixtures? Yes Basement? Yes X No (Initial) Wastewater Flow: 360 Type of Wastewater System** (See note below, if applicable) **NEW Tank** Number of trenches existing Installation Requirements/Conditions Feet on Center Septic Tank Size 1000 gallons Exact length of each trench ___ Trench Spacing: Trenches shall be installed on contour at a Soil Cover: inches Pump Tank Size (Maximum soil cover shall not exceed Maximum Trench Depth of: inches (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ______ft. TDH vs. ___ inches below pipe inches above pipe Aggregate Depth: inches total Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This SEE ATTACHED SITE SKETCH Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 03-08-23 Authorized State Agent: __ Construction Authorization Expiration Date: 03-08-28

Harnett County Department of Public Health Site Sketch

Issued To: Rusty	on: 393 Blanchard Rd (SR 1114) y Frizzelle A Subdivision	Lot #
Authorized State		Date: 03-08-23
		_
		Septic Tanke and recomm
		TO Existing Lines
	14'x70' 3B- SWMH 7' 17' Tank 1-140'	

This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.