



Permit Inspections

Harnett County

Permit Number: **BRES2303-0004**

Description: **35x15 inground pool**

Applied: **3/2/2023**

Approved: **3/2/2023**

Site Address: **428 SILVER MAPLE DR**

Issued: **3/2/2023**

Finalized:

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **ISSUED**

Applicant: **CANEPA LAURA**

Parent Permit:

Owner: **CANEPA LAURA**

Parent Project:

Contractor: **Choice Backyard**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Justin Ryan McLeod		eTRAKiT Inspection Request

Notes:

9/18/2023 11:30 AM Andrew Long

Contact Name: Carmelo Canepa
Site Address: 428 SILVER MAPLE DR
Phone: 9197571800
e-Mail: permits@encorsolar.com

	5/10/2023	5/10/2023	GAS PIPING	Justin Ryan McLeod	APPROVED	
--	-----------	-----------	------------	--------------------	----------	--

Notes:

	5/10/2023	5/10/2023	ELECTRICAL UNDERGROUND	Justin Ryan McLeod	APPROVED	
--	-----------	-----------	------------------------	--------------------	----------	--

Notes:

Also observed bonding wire connected to water bond and in trench up to pool. Ok to to cover trench, bonding around the pool needs to still be looked at.

	5/18/2023	5/18/2023 12:45 PM	ZONING	Kyle Holder	DISAPPROVED	
--	-----------	--------------------	--------	-------------	-------------	--

Notes:

Gate closed beware of dog sign posted

	5/22/2023	5/22/2023 11:30 AM	RESIDENTIAL ZONING	Kyle Holder	APPROVED	
--	-----------	--------------------	--------------------	-------------	----------	--

Notes:



Permit Inspections

Harnett County

	5/30/2023	5/30/2023	BONDING	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
<p>Notes:</p> <p>5/23/2023 11:47 AM Carl Harper Request AM Contact Name: Carl Harper Site Address: 428 SILVER MAPLE DR Phone: 9196751403 e-Mail: schedule@th-electrical.com</p>						