



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

7/12/2023

SUBJECT: BRES2303-0012
BUILDING RESIDENTIAL

To: Delmy Majano

Here are the results of all Inspections located at **18 DANNA ST:**

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ZONING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Planning Bucket
Result:
Remarks:
Notes:

Inspection Type: MH FOUND/MARRIAGE WALL
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 6/13/2023

Completed Date/Time: 6/13/2023

Inspector: Scott Guy

Result: DISAPPROVED

Remarks:

Notes:

-vapor barrier not installed -drain test not installed.-pvc pipe can not be glued to abs pipe.-
drain pipe back falling at the 90 degree fitting. -repair/replace belly fabric and replace missing
insulation.-remove all unused or abandoned electrical conduit and boxes or repair and secure
to code-secure water line per plumbing code -expansion tank on water service required unless
serviced by a private well.- all renovations or alterations from factory design are subject to
residential building code.

Inspection Type: MH FOUND/MARRIAGE WALL

Scheduled Date/Time: 7/12/2023

Completed Date/Time: 7/12/2023

Inspector: John B Kokoszka

Result: DISAPPROVED

Remarks:

Notes:

repair/replace belly fabric and replace missing insulation.-secure water line per plumbing code