

Harnett County Government Complex  
307 W. Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

March 24<sup>th</sup>, 2023

Gina Riccobono Myrick  
377 Mineral Springs Lane  
Fuquay Varina, NC 27526

**RE: Existing Tank Application # BRES2303-0024**

Mr. Martin

An attempt was made to evaluate the above property for issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

\_\_\_ 1. Uncover outlet lid on septic tank and break seal, uncover D-Box. (\$25.00 fee incurred).


\_\_\_ 2. Have system pumped out

\_\_\_ 3. Need site plan

**X 4. Other – Any building structure must be 5' from any part of septic system. Please contact me to discuss options.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.  
Environmental Health Program Specialist  
Harnett County Department of Public Health

JEM/kh  
Copy - Central Permitting