



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

5/17/2023

**SUBJECT: BRES2303-0047**  
**BUILDING RESIDENTIAL**

To: Suzette Dowling

Here are the results of all Inspections located at **1037 ATKINS RD:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ZONING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Planning Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: ELECTRICAL UNDERGROUND  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: BONDING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ELECTRICAL UNDERGROUND

Scheduled Date/Time: 5/16/2023

Completed Date/Time: 5/16/2023

Inspector: Scott Guy

Result: DISAPPROVED

Remarks:

Notes: -Electrical already covered.

Inspection Type: BONDING

Scheduled Date/Time: 5/16/2023

Completed Date/Time: 5/16/2023

Inspector: Scott Guy

Result: DISAPPROVED

Remarks:

Notes: -Bonding grid installed but not correctly. -Jacuzzi Installed without bonding grid.