



Note: Window fall protection must be provided on-site where required in accordance with applicable code.

Notes:

1. Exterior opening headers and jack studs are SPF #2 unless otherwise noted.
2. Sidewall headers may use alternate construction per section B-10 of Systems Manual.
3. LVL's where specified to be minimum of 1 1/2" wide, M.O.E. = 2.0 and fb = 2900 PSI.
4. See C-10-45 for stair opening framing.
5. See C-10-105 for dormer opening framing.

See Schedules and General Notes Page

○ = Column Support Location

⌈ = Attic Access



Note:
* LVL's noted must extend past column on at least one end 24" minimum and be overlaid with OSB sheathing.

Builder: R-Anell Housing Group, LLC - Subsidiary of The Commodore Corp.

Title: Floor Plan

Callout: 3274	Revisions:	Scale: 3/16" = 1'-0"	Date: 10/31/2022	Cust: MCCONNELL
Drawn By: CL	Reference: RJ557-A1			Dir: HBV
				S/N: 43986

Model/Eng. No. 1R2036-V27
FP