

HTE# BRES 2303-0069

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Parwell Pool + Spa PHONE # 910 738-8110

ADDRESS 1380 Lenkham Rd Lumberton N.C. 28358

NAME OF MOBILE HOME PARK OR S/D Thorntons Creek

NAME OF OWNER (IF DIFFERENT) Claude + Mary Shanonk

ADDRESS OF OWNER (IF DIFFERENT) 200 Thorntons Creek Dr Erwin N.C. 28335

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1769 OLD STAGE RD

PURPOSE OF INSPECTION: 12'x28' Inground Pool

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

*SPOKE TO OWNER ABOUT NOT DAMAGING EXISTING SYSTEM - REPAIR IS VERY EXPENSIVE AND CAN BE AVOIDED WITH PROPER PLANNING.

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Manhart IZBAS
Signature of Environmental Health Specialist

4-12-23
Date