

HTE# BRES 2303-0071

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Donald Paeker PHONE # 216-789-8527

ADDRESS 44 Henry Pkale Ln Angier N.C.

NAME OF MOBILE HOME PARK OR S/D Hunters Point Lot 18

NAME OF OWNER (IF DIFFERENT) _____

ADDRESS OF OWNER (IF DIFFERENT) _____

PROPERTY LOCATION: STATE ROAD NAME AND # SR 565 Selas Hayes Rd

PURPOSE OF INSPECTION: 14x25 Attached Garage
The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

* Will change Repair AREA
to True 50% REDUCTION
* BUSH/TREE NEEDS
Removal From
on top of
Pump Tank + Control

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Manhart # RBHS 4-12-23
 Signature of Environmental Health Specialist Date