

HTE# BUS 2304-0026

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Kenneth Harmon PHONE # 910 658-0047

ADDRESS 2195 McKenley St Coats N.C. 27521

NAME OF MOBILE HOME PARK OR S/D Traders Bluff lot 1

NAME OF OWNER (IF DIFFERENT) Billy Harmon

ADDRESS OF OWNER (IF DIFFERENT) 245 Festus Rd Coats N.C. 27521

PROPERTY LOCATION: STATE ROAD NAME AND # 821456 Festus Rd

PURPOSE OF INSPECTION: 28x52 DWMH

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markant ^{EA 2515}
Signature of Environmental Health Specialist

4-27-23
Date