

DESIGN PROFESSIONAL INSPECTION FORM

RECORD OF THE INSPECTION OF A COMPONENT OR ELEMENT BY A NC LICENSED ARCHITECT OR ENGINEER

Project Information:

Residential Single-Family Project: Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Commercial Project: Y <input type="checkbox"/> N <input checked="" type="checkbox"/>
Code Enforcement Project No:	Permit No:
Project Name:	Owner: TAYLOR JONATHAN
Project Address: 4131 US 421 N LILLINGTON, NC 27546	Suite No:
Date Inspected: 7/18/2023	Contractor Name: CAROLINA CONSTRUCTION & RESTORATION
Component Inspected: FOOTING	

Responsible Licensed NC Architect or NC Engineer

Name:	JOE E GODWIN SR.		
Firm Name:	ENOCH ENGINEERS P.A.		
Phone Numbers:	Office: 919-894-7765	Mobile:	
Email Address:	JASON@ENOCHENGINEERS.COM		
Mailing Address:	1403 NC HWY 50 SOUTH, BENSON, NC 27504		

APPLICABLE CODE: 2018 NCRC - SECTION R403

2018 NCBC = 2018 NC Building Code; 2018 NCRC = 2018 NC Residential Code

Describe Element/Component/Type of Inspection: *


RESIDENTIAL FOOTINGS OK PER 2018 NCRC. SOIL BEARING CAPACITY OF 2000PSF MIN.
SOIL REPORT ISSUED UPON REQUEST.

*(subgrade form/letter may also be required)

Attestation/Signature:

By signing below, I certify that the component and/or element of the building as identified on this form has been inspected by me or someone under my direct supervision per subsection (b2) of NC G.S. 153A-352 and is in compliance with the Code or other proposal of the architect or engineer for the project. This inspection is in compliance with all of the requirements of the above referenced Code. Attach any additional documents if needed.

Licensed Architect or Engineer



Inspection Department disclaimer:

Upon the receipt of a signed written document as required under subsection (a) of Article 160A-413.5., Code Enforcement shall be discharged and released from any liabilities, duties and responsibilities imposed by this article or in common law from any claim arising out of or attributed to the component or element in the construction of the building for which the signed written document was submitted. Be aware that this inspection will be noted in all inspection records including the Certificate of Occupancy or Certificate of Compliance. This inspection does not address any local ordinances or zoning requirements.