Harnett County Department of Public Health


Improvement Permit

A building permit cannot be issued with only an Improvement Permit

		PROPE	RTY LOCATI	ON: 237 Adcc	ock Rd (SR 1235)		
ISSUED TO: Nicholas We		SUBDIVISION LOT #					
NEW REPAIR 16'x76' S		Ш		Site Improvements re	quired prior to Construction A	uthorization I	ssuance:
Proposed Wastewater System Type:		n					
Projected Daily Flow: 360	GPD GPD	_					
Number of bedrooms: 3	Number of Occupar	nts: <u>6</u> max					
Basement Yes X No							
Pump Required: Yes No		d based on final location					
Type of Water Supply: Commu	nity 🔀 Public	Well Distance from	n well	feet	Permit valid fo		Five years
Permit conditions:						Ш	No expiration
	11 11	,					
Authorized State Agent::	Moh the	-REHT	Date: 0	7-10-23	SEI	E ATTACHED S	SITE SKETCH
The issuance of this permit by the Health D site is subject to revocation if the site plan, the Laws and Rules for Sewage Treatment an	plat, or the intended use cha	nges. The Improvement Permit si	s. The permit h shall not be af	older is responsible for ch fected by a change in own	ecking with appropriate governing bo nership of the site. This permit is subj	dies in meeting ect to complianc	their requirements. This e with the provisions of
		Construction	on Aut	horization.			
		(Required	for Buildin	g Permit)			
The construction and installation requiremen	ts of Rules .1950, .1952, .195				s into this permit and shall be met. S	systems shall be	installed in accordance
with the attached system layout.							
ISSUED TO: Nicholas We	eaver				Adcock Rd (SR 1		107.11
			SUBDIVISION				LOT #
Facility Type: 16'x76' SW	/MH	New □	Expansio	on 🗌 Repair			
Basement? Yes X N	lo Basement Fixtu	res? 🗌 Yes 🔀 N	No				
Type of Wastewater System**	25% reduction	n			(Initial) Wastewater F	low:	GPD
(See note below, if applicable])						
	25% reducti	on		(Repair)			
Installation Requirements/Conditi	ons	Number of trenches 1	1				
Septic Tank Size 1000		Exact length of each tr		O feet	Trench Spacing: 9	Feet o	on Center
Pump Tank Size		Trenches shall be instal			Soil Cover: 6	inches	
Tump rain size		Maximum Trench Depth			(Maximum soil cover s	hall not exc	eed
		(Trench bottoms shall b			36" above the trench		
		in all directions)	De level to		Jo above the trener	, bottom)	
Duma Danuiramante.	4 TOU	GPM					inches below pipe
Pump Requirements:	_ IL. IUN VS	_0111			Aggregate Denth:		inches above pipe
Conditions:					Aggregate Depth:		inches total
Conditions.							
WATER LINES (INCLUDING IR NO UTILITIES ALLOWED IN IN			ART OF SE	PTIC SYSTEM OR	REPAIR AREA.		
**If applicable: I understand the	system type specified	is different from the typ	pe specified	d on the application	n. I accept the specification	s of this per	rmit.
Owner/Logal Representative Sign	aturo:				Date:		
Owner/Legal Representative Signature:							
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of Relaws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH							
The second residence is applied to com-	111	/		- Learn and to the tolle	Provide Learning		2000 OF 16174 THE STATE OF THE
Authorized State Agent: Mak A REHT Date: 07-10-23							
Authorized State Agent:							
Construction Authorization Expiration Date: 07-10-28							

Harnett County Department of Public Health Site Sketch

Property Location: 237 Adcock F	Rd (SR 1235)	
Issued To: Nicholas Weaver	/ Subdivision	Lot #
Authorized State Agent:	Male le REH	Date: 07-10-23



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.