



- * Per owner, windows at hot tub to be removed/closed up. Hot tub shall have a code compliant safety cover
- * Per contractor, all slabs, including existing patio, to have code compliant footings.
- * Rrafters to be 2x8, CJ to be 2x6, both at 16" on center. Collar ties are also required.
- * Headers and jack/king studs to be code compliant.



- Doors
- Windows