



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

7/18/2023

SUBJECT: BRES2304-0064
BUILDING RESIDENTIAL

To: Adrian Hunt

Here are the results of all Inspections located at **189 SHEPARD DR:**

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time:
Completed Date/Time:
Inspector: EH Bucket
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Steven Gazlay
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time: 5/17/2023
Completed Date/Time: 5/17/2023
Inspector: John B Kokoszka
Result: CANCELLED
Remarks:
Notes: not ready / also wrong inspection scheduled

Inspection Type: MONO SLAB
Scheduled Date/Time: 5/18/2023
Completed Date/Time: 5/18/2023
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: Mono slab not formed up and need plans on site and footings need to be cleaned out

Inspection Type: MONO SLAB
Scheduled Date/Time: 5/19/2023
Completed Date/Time: 5/19/2023
Inspector: James T Hall
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 6/14/2023
Completed Date/Time: 6/14/2023
Inspector: James T Hall
Result: DISAPPROVED

Remarks:

Notes: 1.Anchor bolts 1' from house wall
2.Missing collar ties per code
3.Need ladder to be able to see attached rafters to existing roof
4.Need 5 nails from ceiling into rafters

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 6/16/2023
Completed Date/Time: 6/16/2023
Inspector: James T Hall
Result: APPROVED

Remarks:

Notes:

Inspection Type: INSULATION
Scheduled Date/Time: 6/20/2023
Completed Date/Time: 6/20/2023
Inspector: James T Hall
Result: APPROVED

Remarks:

Notes:

Inspection Type: FINAL**
Scheduled Date/Time: 7/18/2023
Completed Date/Time:
Inspector: James T Hall
Result:

Remarks:

Notes: