

**From:** Rita Perry <ritaperry1962@gmail.com>  
**Sent:** Friday, May 5, 2023 2:56 PM  
**To:** Brad Sutton  
**Cc:** Craig Harris  
**Subject:** Re: 189 Shepard Dr

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good Afternoon, Brad,

Please give me a call at 9109850813 to get clarification of exactly what we need to provide.

Thank you  
Rita Perry Harris

On Fri, May 5, 2023 at 1:32 PM Craig Harris <[craig.harris1966@gmail.com](mailto:craig.harris1966@gmail.com)> wrote:

Adrian,

Called over today and this is the information I got from the permit office. Were you aware of this?

Craig

----- Forwarded message -----

**From:** Kimberly Gibbons <[kgibbons@harnett.org](mailto:kgibbons@harnett.org)>  
**Date:** Fri, May 5, 2023 at 1:27 PM  
**Subject:** 189 Shepard Dr  
**To:** [craig.harris1966@gmail.com](mailto:craig.harris1966@gmail.com) <[craig.harris1966@gmail.com](mailto:craig.harris1966@gmail.com)>

## View Notes



**BRES2304-0064**

Type (Asc) ▼

**GO**

### **REVIEWS**

Brad Sutton

RESIDENTIAL  
BUILDING

Need construction drawings from footing through roof. Room may not be built on a 4 inch concrete slab.

Windows adjacent to hot tub must be replaced with tempered glass.

Room may not enclose any existing bedroom windows

4/25/2023 11:37:05 AM

**Close**

Kimberly Gibbons

Central Permitting Technician

Harnett County Development Services

420 Mckinney Parkway

P.O. Box 65 (Mailing)

Lillington, N.C. 27546

(910) 893-7525 opt.1

[kgibbons@harnett.org](mailto:kgibbons@harnett.org)