

HTE #: BRES 2304-0079

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

Name: Mario Hernandez Phone #: 1-919-454-0953

Address: 705 Avery Pond Dr

Name of Mobile Home Park or S/D: Avery Pond lot 112

Name of Owner (if different): _____

Address of Owner (if different): _____

Property Location (State Road name and #): SR 1429 Chalkeats RD

Purpose of Inspection: 38X18 Inground Pool

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

** Spoke with owner about problems that can arise from pool install. * Repair has changed to 50% pool
* Don't drive over septic system*

THIS INSPECTION IS VOID IF:

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markham JR *RES*
Signature of Environmental Health Specialist

5-15-23

Date