inches above pipe

inches total

Aggregate Depth:

## Harnett County Department of Public Health

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 131 Pine Oak (SR 2612) ISSUED TO: Makeda Mason SUBDIVISION Sweetbriar Estates EXPANSION REPAIR Site Improvements required prior to Construction Authorization Issuance: NEW X Type of Structure: 28'x68' DWMH Proposed Wastewater System Type: 25% reduction Projected Daily Flow: 480 GPD Number of bedrooms: 4 Number of Occupants: 8 X No Basement Yes X No Pump Required: Yes May be required based on final location and elevations of facilities Type of Water Supply: Community Public Well Distance from well feet X Five years Permit valid for: ■ No expiration Permit conditions: Date: 06-01-23 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 131 Pine Oak (SR 2612) ISSUED TO: Makeda Mason SUBDIVISION Sweetbriar Estates Facility Type: 28'x68' DWMH Expansion Basement? Yes X No Basement Fixtures? Yes X No 25% reduction Type of Wastewater System\*\* (Initial) Wastewater Flow: 480 GPD (See note below, if applicable ) 25% reduction Number of trenches 1 Installation Requirements/Conditions Septic Tank Size 1000 Exact length of each trench 180 \_\_\_ Feet on Center Trench Spacing: 9 gallons Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches Maximum Trench Depth of: 18-30 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. \_ inches below pipe

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

Conditions:

NO UTILITIES ALLOWED IN INITIAL OK KEPAIK DRAIN FIELD AKEA.		
**If applicable: I understand the system type specified is different from the type specified on the application. I accept	the specifications of this permit.	
Owner/Legal Representative Signature:	Date:	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred	when there is a change in ownership of the site. This	


Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: Note the REHT Date: 06-01-23

Construction Authorization Expiration Date: 06-01-28

## Harnett County Department of Public Health Site Sketch



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.