

HTE #: BUS 2305-0062

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: Southern Tide Homes Phone #: 919 369 7804

Address: 11917 NC Hwy 210 Benson N.C. 27504

Name of Mobile Home Park or S/D: \_\_\_\_\_

Name of Owner (if different): Darrt Pleasant

Address of Owner (if different): 821 Guy Rd Anglen N.C. 27801

Property Location (State Road name and #): 81506 Guy Rd

Purpose of Inspection: 7 x 12 Bonus/Office Room Only

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.

\* TANK WAS 5' OFF <sup>Project</sup> Addition  
\* WRONG END OF TANK UNCOVERED

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James C. Marshall JR 725115  
Signature of Environmental Health Specialist

6-27-23  
Date