



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

10/4/2023

**SUBJECT: BRES2305-0065**  
**BUILDING RESIDENTIAL**

To:

Here are the results of all Inspections located at **200 WOMACK RD:**

Inspection Type: FOOTING  
Scheduled Date/Time: 7/3/2023  
Completed Date/Time: 7/3/2023  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks:  
Notes: Inspector BS changed the inspection assignment from BS to DLF  
Needs 4x8x16 blocks under each post, needs sds screws into post through exterior girders

Inspection Type: FOOTING  
Scheduled Date/Time: 8/15/2023  
Completed Date/Time: 8/15/2023  
Inspector: Steven Gazlay  
Result: CANCELLED  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 8/17/2023  
Completed Date/Time: 8/17/2023  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: spg changed Inspection Date/Time from 08/16/2023 to 08/17/2023

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 9/7/2023  
Completed Date/Time: 9/7/2023  
Inspector: John B Kokoszka  
Result: CANCELLED  
Remarks:  
Notes: Ron called to cancel





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 9/13/2023  
Completed Date/Time: 9/13/2023  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Ground needs to be level and backfilled at first step.

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 9/25/2023  
Completed Date/Time: 9/25/2023  
Inspector: James T Hall  
Result: DISAPPROVED  
Remarks:  
Notes: Gate locked

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 10/3/2023  
Completed Date/Time: 10/3/2023  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes: