

HTE #: 2782S 2306-0017

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: NATALIE + Michael Gifford Phone #: 415-748-8257

Address: 1986 NEIGHBORS RD DUNN N.C. 28334

Name of Mobile Home Park or S/D: 6+2

Name of Owner (if different): \_\_\_\_\_

Address of Owner (if different): \_\_\_\_\_

Property Location (State Road name and #): In 1707 Neighbors Rd

Purpose of Inspection: 18' x 18' x 48" Above Ground Pool

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.


*\*Spoke with owner about pool being 12' off of septic manholes - Advised to move over toward P/L and back toward S/D*

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
Signature of Environmental Health Specialist

6-28-23  
Date