



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

11/7/2023

**SUBJECT: BRES2306-0022**  
**BUILDING RESIDENTIAL**

To: KARA HOMES, INC.

Here are the results of all Inspections located at **409 LAMBERT LN:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: MONO SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOOTING  
Scheduled Date/Time: 9/6/2023  
Completed Date/Time: 9/6/2023  
Inspector: Daniel L Floyd  
Result: DISAPPROVED

Remarks:

Notes: For mono slab configuration the footing needs to go all the way around the building. As shown on foundation plan for a turndown slab.

Inspection Type: FOOTING  
Scheduled Date/Time: 9/8/2023  
Completed Date/Time: 9/8/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED

Remarks:

Notes: Previous item done. Footing is continuous

Inspection Type: ROUGH IN  
Scheduled Date/Time: 10/10/2023  
Completed Date/Time: 10/10/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED

Remarks:

Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 11/1/2023  
Completed Date/Time: 11/1/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED

Remarks:

Notes: Step wasn't code height outside but homeowner shoveled dirt to correct while I was in the neighborhood. Stated he was gonna fill the area soon with pea stone and landscape.