



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/9/2023

SUBJECT: BRES2306-0058
BUILDING RESIDENTIAL

To: NEPSTAD HOME BUILDERS

Here are the results of all Inspections located at **78 CEDAR DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: James T Hall
Result:
Remarks:
Notes:

Inspection Type: T-POLE
Scheduled Date/Time: 7/10/2023
Completed Date/Time: 7/10/2023
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: NO T-pole on site



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: T-POLE
Scheduled Date/Time: 7/25/2023
Completed Date/Time: 7/25/2023
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/3/2023
Completed Date/Time: 8/3/2023
Inspector: John B Kokoszka
Result: DISAPPROVED
Remarks:
Notes: All Trades permit
House was locked

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 8/7/2023
Completed Date/Time: 8/7/2023
Inspector: James T Hall
Result: DISAPPROVED
Remarks:
Notes: lock box is 2010

1.Roof boots2.Seal inside of plumbing sleeve in garage and need a chase for it3.Fire caulk water lines in bottom plate in garage on house wall4.Missing insulation baffles5.Missing nailers on bathroom tubs

