

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

July 17, 2023

Donnie Simpson
250 Kinnis Creek Drive
Angier NC 27501

RE: Existing Tank Application # BRES2306-0060

Mr. Simpson:

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover Outlet lid on septic tank and break seal. (\$25.00 fee incurred).
- 2. Have system pumped out
- 3. Replace Sanitary T
- 4. **Other – Line goes under proposed addition. Setback not met. Must meet setback of 5' off any structure.**

Your application will be put on hold until the selected items above have been addressed. When completed, **call (910) 893-7525 Ext. 1 to confirm** that the items mentioned have been corrected. We will then reschedule your property for evaluation.

Sincerely,



James Manhart, R. E. H. S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JM/slc
Copy - Central Permitting