



Permit Inspections

Harnett County

Permit Number: BRES2306-0068

Description: 12x30 inground pool

Applied: 6/29/2023

Approved: 7/18/2023

Site Address: 238 PRINCE PLACE DR

Issued: 7/18/2023

Finalized: 1/25/2024

City, State Zip Code: FUQUAY-VARINA, NC 27526

Status: FINALED

Applicant: PARROT BAY POOLS AND SPAS INC

Parent Permit:

Owner: COWAN DAVID R

Parent Project:

Contractor: PARROT BAY POOLS AND SPAS INC

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	8/25/2023	8/25/2023	ELECTRICAL UNDERGROUND	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
Notes: 8/24/2023 1:45 PM Cheryl Canders Contact Name: Cheryl Canders Site Address: 238 PRINCE PLACE DR Phone: 9192570878 e-Mail: cheryl@parrotbaypoolsnc.com						
	9/7/2023	9/7/2023	BONDING	Justin Ryan McLeod	APPROVED	eTRAKiT Inspection Request
Notes: 9/5/2023 4:17 PM Cheryl Canders Contact Name: Austin Cornett Site Address: 238 PRINCE PLACE DR Phone: 9192570878 e-Mail: austin@parrotbaypoolsnc.com Non conductive liner with equipotential bond ring 18-24 inches from perimeter circling pool and bonded to water at pump.						
	12/12/2023	12/12/2023	09:15 AM ZONING	Randy Baker	APPROVED	
Notes:						
	1/8/2024	1/8/2024	FINAL**	Justin Ryan McLeod	DISAPPROVED	
Notes: Heated pool requires class 1 vapor retardant cover						
	1/25/2024	1/25/2024	FINAL**	Justin Ryan McLeod	APPROVED	
Notes:						