



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

11/17/2025

SUBJECT: **BRES2307-0024**  
**BUILDING RESIDENTIAL**

To: STAFFORD MARTHA BYRD

Here are the results of all Inspections located at **1614 MCLAMB RD:**

Inspection Type: ADDRESS  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: GIS Bucket  
Result:  
Remarks:  
Notes:

Inspection Type: MONO SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Deen Taylor  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: FOOTING  
Scheduled Date/Time: 1/8/2024  
Completed Date/Time: 1/8/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time: 2/5/2024  
Completed Date/Time: 2/5/2024  
Inspector: Deen Taylor  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 10/4/2024  
Completed Date/Time: 10/4/2024  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:

Notes: 2x6 Floor joist over spanned. Block plywood wall seams within 3 foot of corner. Plywood turned wrong direction on roof and floor. Need 3 king studs each side of double doors. Missing header over gable windows. Laterally unsupported wall studs over 10 feet. Box headers not nailed. Anchor bolts not

Inspection Type: FINAL\*\*  
Scheduled Date/Time: 1/21/2025  
Completed Date/Time: 1/21/2025  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:

Notes: Eng. Letter is attachments