


# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) James Wilkins     New Installation     Septic Tank  
 Property Location: SR# 1412     Repairs     Nitrification Line  
 Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: Otis Strickland    Registration # 12  
 Basement with Plumbing:     Garage:   
 Water Supply:  Well     Public     Community  
 Distance From Well: 50+ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional     Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons    Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field: No. of ditches 3 exact length of each ditch 115 ft. width of ditches 3 ft. depth of ditches 18-20 in.  
 French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 10259    Date: 8/2/95  
 Inspected by: James E. M... R  
Pete A. Duke  
 Environmental Health Specialist



# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Jama Wilkens  New Installation  Septic Tank  
Property Location: SR# 1412  Repairs  Nitrification Line

Subdivision - Lot # B  
Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Number of Bedrooms Proposed: 3 Lot Size: 12 acres

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field No. of ditches 3 exact length of each ditch 115 ft. width of ditches 5 ft. depth of ditches 18-20 in.  
French Drain required: - Linear feet

This permit is subject to revocation if site plans or intended use change. Date: 12-9-94  
Signed: James E. Marbat  
Environmental Health Specialist

VOID AFTER 5 YEARS SR 1412 - > to LILLINGTON

