



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

9/5/2024

**SUBJECT: BRES2307-0049**  
**BUILDING RESIDENTIAL**

To: DSW Homes, LLC

Here are the results of all Inspections located at **995 SHAWTOWN RD:**

Inspection Type: FINAL\*\*  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: MONO SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: OPEN FLOOR  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: ROUGH IN  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: SLAB  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: UNDER SLAB TRADES  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks:  
Notes:

Inspection Type: INSULATION REINSPECTION  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: James T Hall  
Result:  
Remarks: eTRAKiT Inspection Request  
Notes:





**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: INSULATION  
Scheduled Date/Time: 4/24/2024  
Completed Date/Time: 4/24/2024  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 4/22/2024 4:56 PM Paul Judson  
Lockbox code is 9997. Project Manager #: 910-273-7002  
Contact Name: Paul Judson  
Site Address: 995 SHAWTOWN RD  
Phone: 2526718118  
e-Mail: ncadmin@dswhomes.com

Need to seal around all exterior openings and plate penetrations. House will have to have smoke detectors and circuit brought up to current code.

Inspection Type: INSULATION REINSPECTION  
Scheduled Date/Time: 7/2/2024  
Completed Date/Time: 7/2/2024  
Inspector: Daniel L Floyd  
Result: DISAPPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: Items from last inspection not corrected