



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

10/12/2023

**SUBJECT: BRES2307-0060**  
**BUILDING RESIDENTIAL**

To: Campbell Kim

Here are the results of all Inspections located at **975 CHRISTIAN LIGHT RD:**

Inspection Type: FOOTING  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Justin Ryan McLeod  
Result:  
Remarks:  
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time: 9/7/2023  
Completed Date/Time: 9/8/2023  
Inspector: James Manhart  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: MH FOUND/MARRIAGE WALL  
Scheduled Date/Time: 9/12/2023  
Completed Date/Time: 9/12/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/11/2023 10:42 AM Michelle Hartley

Contact Name: Michelle Hartley  
Site Address: 975 CHRISTIAN LIGHT RD  
Phone: 9108920108  
e-Mail: michelle.hartley@claytonhomes.com



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: ADDRESS  
Scheduled Date/Time: 9/21/2023  
Completed Date/Time: 9/21/2023  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/20/2023 9:46 AM Michelle Hartley

Contact Name: Michelle Hartley  
Site Address: 975 CHRISTIAN LIGHT RD  
Phone: 9108920108  
e-Mail: michelle.hartley@claytonhomes.com

975 CHRISTIAN LIGHT RD FUQUAY VARINA 27526.

Inspection Type: ZONING  
Scheduled Date/Time: 9/22/2023  
Completed Date/Time: 9/22/2023 12:45 PM  
Inspector: Kyle Holder  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/21/2023 10:11 AM Michelle Hartley

Contact Name: Michelle Hartley  
Site Address: 975 CHRISTIAN LIGHT RD  
Phone: 9108920108  
e-Mail: michelle.hartley@claytonhomes.com

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 9/25/2023  
Completed Date/Time: 9/25/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/22/2023 8:57 AM Michelle Hartley

Contact Name: Michelle Hartley  
Site Address: 975 CHRISTIAN LIGHT RD  
Phone: 9108920108  
e-Mail: michelle.hartley@claytonhomes.com



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 9/25/2023  
Completed Date/Time: 9/25/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks: eTRAKiT Inspection Request  
Notes: 9/22/2023 8:56 AM Michelle Hartley

Contact Name: Michelle Hartley  
Site Address: 975 CHRISTIAN LIGHT RD  
Phone: 9108920108  
e-Mail: michelle.hartley@claytonhomes.com

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time: 10/9/2023  
Completed Date/Time: 10/9/2023  
Inspector: Justin Ryan McLeod  
Result: DISAPPROVED  
Remarks:  
Notes: lock box is 1872

Cannot locate ground rods, outside breaker panel will not latch close. Water and sewer lines not covered.

Inspection Type: MFH FINAL\*\*  
Scheduled Date/Time: 10/11/2023  
Completed Date/Time: 10/11/2023  
Inspector: Justin Ryan McLeod  
Result: APPROVED  
Remarks:  
Notes: