



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

8/29/2023

SUBJECT: BRES2307-0063
BUILDING RESIDENTIAL

To: GILMAN TERRY WAYNE

Here are the results of all Inspections located at **262 HUNTING WOOD DR:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 8/23/2023
Completed Date/Time: 8/23/2023
Inspector: Daniel L Floyd
Result: DISAPPROVED

Remarks:

Notes: Inspector JRM changed the inspection assignment from JRM to DLF
No answer at the door couldn't do inspection

Inspection Type: ROUGH IN REINSPECT
Scheduled Date/Time: 8/28/2023
Completed Date/Time: 8/28/2023
Inspector: Daniel L Floyd
Result: DISAPPROVED

Remarks:

Notes: Owner gives permission to go in fence. There are no dogs.
Need Simpson LRU hangers on all rafters per plan not hurricane clips and missing some nails in hurricane clips