



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

9/29/2023

SUBJECT: BRES2307-0070
BUILDING RESIDENTIAL

To: KELLER JOSEPH

Here are the results of all Inspections located at **5985 RAWLS CHURCH RD:**

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time:
Completed Date/Time:
Inspector: EH Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: FOUNDATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: INSULATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: MONO SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: SLAB
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:

Inspection Type: UNDER SLAB TRADES
Scheduled Date/Time:
Completed Date/Time:
Inspector: Justin Ryan McLeod
Result:
Remarks:
Notes:





Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ROUGH IN REINSPECT

Scheduled Date/Time:

Completed Date/Time:

Inspector: Justin Ryan McLeod

Result:

Remarks:

Notes:

Inspection Type: ROUGH IN

Scheduled Date/Time: 9/18/2023

Completed Date/Time: 9/18/2023

Inspector: Justin Ryan McLeod

Result: DISAPPROVED

Remarks:

Notes:

1. Wire nuts on not landed wires in panel, 2. Joist hangers above range 3. Wall two need double 2x10s under jacks per letter n basement and joist hangers at same. 4. fire block penetrations to top and bottom plate.